

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

(1) OWNER: Name W H D BRY SAORES Address 2231 E 1ST PT. DRIVE LAKES 98280

(2) LOCATION OF WELL: County ISLAND - SW 1/4 Sec 13 T30 N. R2E W.M.

Bearing and distance from section or subdivision corner 1470'SD 550E. CENTER SEC 13

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 34 ft. Depth of completed well 314 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from 0 ft. to 300 ft.
Threaded ☐ " Diam. from _____ ft. to _____ ft.
Welded ☒ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☐
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name JOHNSTON
Type SS W/LA Model No. _____
Diam. 6 Slot size 8 from 300 ft. to 314 ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☐ Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 25 ft.
Material used in seal DEMOLITE
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation 250 ft.
above mean sea level.
Static level 250 ft. below top of well Date _____
Artesian pressure _____ lbs per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft drawdown after _____ hrs.
" " " " " "
" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test 20 gal./min. with 5 ft. drawdown after 2 1/2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN GR	0	40
SAND YELLY GR	40	95
DRY SAND GR	95	200
SAND W/ FINE GR	200	300
SAND MED W/ GR	300	314

RECEIVED
JAN 23 1987
DEPARTMENT OF ECOLOGY
NORTHWEST REGION

Work started 10/1/86 19____ Completed 10/28 1986

WELL DRILLER'S STATEMENT:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BRY DRILLING (Person, firm, or corporation) (Type or print)
Address 41087 EPRICK RD CLATSOP
[Signed] Jerry Lohman (Well Driller)
License No. 204 Date 11/12/86 19____